



Marine & Offshore
Division

Certificate number: 14036/C2 MED

File number: ACI 4000/055/001

Item number: MED/3.27b

USCG Module B number: 164.138 / EC2690

*This certificate is not valid when presented without the full
attached schedule composed of 7 sections*

www.veristar.com

Notified Body 2690 - MARINE EQUIPMENT DIRECTIVE 2014/90/EU

EC TYPE EXAMINATION CERTIFICATE

as per Module B of Directive 2014/90/EU of the European Parliament and of the Council of 23 July 2014 as transposed in the French Regulations and Commission Implementing Regulation (EU) 2017/306 of 06 Feb. 2017

This certificate is issued to:

UNIFRAX

LORETTE - FRANCE

for the type of product

**PENETRATIONS THROUGH 'B' CLASS DIVISIONS: PIPE, DUCT, TRUNK, etc,
PENETRATIONS**

B-15 Class bulkhead's PVC pipe penetrations (Restricted application, see §4.1)

Requirements:

SOLAS 74 convention as amended, Regulations II-2/9

IMO Res. MSC.61(67) -(FTP Code)- Annex 1 Part 3 with IMO Res MSC.307(88) -(2010 FTP Code)- article 8

IMO MSC/Circ.1120

This certificate is issued on behalf of the French Maritime Authorities to attest that BUREAU VERITAS did undertake the relevant type-examination procedures for the product identified above which was found to comply with the relevant requirements of the Directive 2014/90/EU of the European Parliament and of the Council of 23 July 2014 as transposed in the French Regulations.


This certificate will expire on: 22 Jul 2019

For BUREAU VERITAS Notified Body 2690,

At BV LONDON, on 26 Apr 2017,

Spencer Yule



This certificate does not allow to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark ) to the products corresponding to this type. To this end, the production-control phase module (D, E or F) of Annex II of the Directive is to be complied with and controlled by a written inspection agreement with a notified body.

This certificate remains valid until the date stated above, unless cancelled or revoked, provided the conditions indicated in the subsequent page(s) are complied with and the product remains satisfactory in service. This certificate will not be valid if the applicant makes any changes or modifications to the approved product, which have not been notified to, and agreed in writing with BUREAU VERITAS. Should the specified regulations or standards be amended during the validity of this certificate, the product(s) is/are to be re-approved prior to it/they being placed on board vessels to which the amended regulations or standards apply. BUREAU VERITAS is designated by the French Maritime Authority as a "notified body" under the terms of the French Regulations Division 140 Chapter 140-2. This certificate is issued within the scope of the General Conditions of BUREAU VERITAS Marine & Offshore Division available on the internet site www.veristar.com. Any Person not a party to the contract pursuant to which this document is delivered may not assert a claim against BUREAU VERITAS for any liability arising out of errors or omissions which may be contained in said document, or for errors of judgement, fault or negligence committed by personnel of the Society or of its Agents in establishment or issuance of this document, and in connection with any activities for which it may provide.

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION:

PVC pipe penetrations

Opening in the B-15 class extent : 160 mm in diameter.

PVC pipe, diameter 160 mm (classified M1).

Intumescent sealant KBS SEALANT applied only on exposed side :

- over 50 mm around penetration (10 mm thick)

- along 200 mm on pipe (2 mm thick).

2. DOCUMENTS AND DRAWINGS:

As per the Manufacturer's drawings N° 03 2004 rev A.

3. TEST REPORTS:

Test report N° 576/03/A/NP/R 102, issued on 02.09.2003, as per IMO FTP Code, Part 3 from GERBAM Laboratories, France.

4. APPLICATION / LIMITATION:

4.1 - Restricted application : the used sealant had been applied only on one side (exposed side) but unless it is possible, when the penetrations are installed on board, to determine from which side the fire could come, it is necessary to apply the sealant on both sides.

4.2 - The fitting aboard to be the same as used for the test.

5. PRODUCTION SURVEY REQUIREMENTS:

5.1 - This certificate alone does not allow the applicant to issue the Declaration of Conformity and to affix the mark of conformity (wheelmark) to the products corresponding to this type. To this end, the production-control phase module D "Production Quality Assurance" or E "Product Quality Assurance" or F "Product Verification" of Annex II of the Directive is to be complied with and controlled by a written inspection agreement with a Notified Body.

5.2 - For information concerning the production phase modules, **UNIFRAX** has declared the following manufacturing site(s):

either: **UNIFRAX Limited**, Mill Lane, Rainford, St Helens, Meyrseaside, WA 11 8LP, The United Kingdom,

or : **UNIFRAX France**, 17 Rue Antoine Durafour, F-42420, Lorette - France,

or : **UNIFRAX India Private Ltd**, 99 k Stone, Ahmedabad Surendrangar Hwy, Lakhtar, Dist. Surendrangar, Gujarat, 382 775, India,

or : **UNIFRAX Brazil Ltda**, Avenida Independencia, 7033, Bairro Sao Matheus, Vinhedo, SP 13280-000, Brazil.

or : **UNIFRAX (Suzhou) Limited**, 59 Shiyuang Road, Xushuguan New Zone, 215151 Suzhou, China.

6. MARKING OF PRODUCT:

6.1 - Reference is made to MED 2014/90/EU chapter 2.

In particular Article 10.3 specifies that the wheelmark shall be followed by the identification number of the Notified Body involved in the production control phase (module D, E or F) and by the year in which the mark is affixed (4 digits or last 2 digits).

6.2 - In pursuance of the EU/US MRA+, and in accordance with the Council Decision 2004/425/EC of 21 April 2004, the product(s) marked as per MED 2014/90/EU may be marked with the USCG conformity marking as authorized by the Notified Body undertaking surveillance module.

7. OTHERS:

7.1 - It is **UNIFRAX**'s responsibility to inform shipbuilders or their sub-contractors of the proper methods of fitting, use and general maintenance of the approved equipment and the conditions of this approval.

7.2 - This certificate supersedes EC Type Examination Certificate n° 14036/C1 MED issued on 19/04/2017 by the Society.

*** END OF CERTIFICATE ***